

THE WATER WORKS & SEWER BOARD OF THE CITY OF
ANNISTON

ADDENDUM NO. 1
01/19/2018

SEWER PIPELINE
REHABILITATION PROJECT
PIR NO. 6173

POINT REPAIRS

The videos included in Exhibits 5, 5a, 6, and 6a indicate that point repairs are required prior to lining of the pipes.

In particular, Pipe 2482 has approximately 40 feet from 413ft to 453ft that requires repair.

Pipe 2472 has approximately 10 feet from 443ft to 453ft that requires repair.

POINT REPAIRS ARE NOT INCLUDED IN THE SCOPE OF THIS CONTRACT AND WILL BE ADDRESSED BY THE OWNER PRIOR TO THE BEGINNING OF THE WORK IN THIS CONTRACT.