

Water Quality Report

For Period Ending December 2017



Anniston Water Works & Sewer Board

931 Noble Street, Suite 200, Anniston, AL 36201

www.awwsb.org

Phone: 256-241-2000

Fax: 256-236-1532

PWS ID Number AL0000133

Got Tap Water?

Anniston Water Works is home to some of the best tasting water. Unfortunately, many people don't take the time to enjoy the quality beverage we serve on tap. Here are a few benefits to making Anniston Water Works Tap Water your beverage of choice.

Water May Help You Look Better!

Water may be able to help you lose weight. Water can make you feel full, which can keep you from taking in too many calories. It can also help to flush the digestive tract and the toxins along with it. The more water you drink, the more likely your body is going to stay clean, slim, and healthy. Another way it may help you feel better is by clearing the skin. When you get those toxins out of your body with water, you will have less instances of acne, more supple skin, and a softer more youthful appearance overall.

Water Helps You Think and Increases Energy!

Your body is composed of about 60% water. But what you may not have known is that your brain is also a huge percentage water. In fact, the little parts of your brain that carry messages are almost 90% water. This means that when you are dehydrated, this part of your brain suffers greatly. Drinking more water can keep these connections healthy, which can then improve your ability to focus and concentrate. As an added bonus, your energy levels are also boosted.

Water Can Eliminate Pain!

If you get dehydrated enough, your body can shut down and you can die. Dehydration can cause pain in the body. Stomach cramps, stiff joints, cramping muscles, and headaches are just a few of the pains that can come from a lack of water. Stick to water and you may find many aches and pains fall by the wayside.

Water Boosts Immune System!

A water guzzler is less likely to get sick. And who wouldn't rather feel healthy the majority of the time? Drinking plenty of water helps fight against flu, cancer and other ailments like heart attacks.

Water Saves Money!

Water is less expensive than sodas or gourmet coffee. Twenty-five (25) glasses of Anniston Tap Water costs less than one (1) cent.

If you still don't think water is worth the switch, try a trial run. Drink water for one week or 3 days or whatever you find to be do-able. Though it might be challenging at first, you will quickly find that water is truly the way to go. Drink your fair share of H₂O and see your health improve right before your eyes.

Ed Turner, General Manager

Este informe contiene la información importante! Si usted no entiende este informe, pida que alguien lo traduzca usted.

**DETECTED SUBSTANCES TABLE FOR PERIOD
JANUARY -- DECEMBER 2017**

Water Source				Coldwater Spring	Hillabee Reservoir		
Primary Inorganic Substances	Units	MCL	MCLG	Highest Level Last 12 Months		Violation (Yes/No)	Source of Substance
Barium	ppb	2000	2000	21.9	11.5	No	Discharge of drilling wastes; discharge from metals refineries; erosion of natural deposits
Chromium	ppb	100	100	2.15	<1.00	No	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride	ppm	4	4	0.748	0.7	No	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate (as N)	ppb	10	10	0.274	<0.200	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sulfate	ppm	500	--	2.14	21.2	No	Erosion of natural deposits
Secondary Inorganic Substances	Units	MCL	MCLG	Highest Level Last 12 Months		Violation (Yes/No)	Source of Substance
Alkalinity, Total	ppm	--	--	106	6.83	No	Erosion of natural deposits
Aluminum	ppb	200	--	<3.00	23.9	No	Water additive for removing organics; Erosion of natural deposits
Calcium	ppm	--	--	22.6	12.1	No	Erosion of natural deposits
Carbon Dioxide	ppm	--	--	4.4	2.64	No	Erosion of natural deposits
Chloride	ppm	250	--	2.69	5.14	No	An inorganic constituent in water affecting taste
Conductance	umhos/cm	--	--	198	94.5	No	Erosion of natural deposits
Copper	ppb	1300	1300	12.1	2.19	No	Corrosion of household plumbing systems; Erosion of natural deposits
Hardness, Total (As CaCO ₃)	ppm	--	--	109	36.4	No	Erosion of natural deposits
Iron	ppb	300	--	<60.0	83.1	No	Erosion of natural deposits
Magnesium	ppm	--	--	11.5	1.29	No	Erosion of natural deposits
Manganese	ppb	50	--	<1.00	3.38	No	Erosion of natural deposits
pH	SU	--	--	7.6	6.3	No	An indicator of acidity or alkalinity levels of water
Sodium	ppm	--	--	1.23	1.92	No	Erosion of natural deposits
Total Dissolved Solids	ppm	500	--	120	64	No	Erosion of natural deposits
Zinc	ppb	5000	--	<5.00	6.89	No	Erosion of natural deposits
Disinfection By-Products (at the Plants)	Units	MCL	MCLG	Highest Level Last 12 Months		Violation (Yes/No)	Source of Substance
Total Trihalomethanes (TTHM's)	ppb	80	0	Less than 2.0	43.0	No	By-product of drinking water chlorination
Haloacetic Acids (HAA5's)	ppb	60	0	Sampling not required in 2017	60.9	No	By-product of drinking water chlorination
Disinfection By-Products (in Distribution System)	Units	MCL	MCLG	Highest Level Last 12 Months		Violation (Yes/No)	Source of Substance
Total Trihalomethanes (TTHM's)	ppb	80	0	20.5		No	By-product of drinking water chlorination
Haloacetic Acids (HAA5's)	ppb	60	0	10.7		No	By-product of drinking water chlorination
Total Trihalomethanes (TTHM's) are the sum of the concentrations of bromoform, bromodichloromethane, chlorodibromomethane, and chloroform MCL equal to or less than 80 ppb. Haloacetic Acids (HAA5's) are the sum of the concentrations of dibromoacetic acid, dichloroacetic acid, monobromoacetic acid, and trichloroacetic acid MCL equal to or less than 60 ppb.							
Unregulated Volatile Chemicals	Units	MCL	MCLG	Highest Level Last 12 Months		Violation (Yes/No)	Source of Substance
Bromodichloromethane	ppb	N/A	0	Less than 0.5	4.30	No	By-product of drinking water chlorination
Chloroform	ppb	N/A	0.07	Less than 0.5	38.0	No	By-product of drinking water chlorination
Dibromochloromethane	ppb	N/A	0.06	Less than 0.5	Less than 0.5	No	By-product of drinking water chlorination
Bromoform	ppb	N/A	0	Less than 0.5	Less than 0.5	No	By-product of drinking water chlorination
Radionuclides	Units	MCL	MCLG	Water Sources: Coldwater Spring and Hillabee Reservoir		Violation (Yes/No)	Source of Substance
Gross Alpha	pCi/l	15	0	Not required in 2017	0.02 +/- 1.25	No	Erosion of natural deposits
Radium	pCi/l	5	--	Not required in 2017	-0.34 +/- 0.50	No	Erosion of natural deposits
When gross alpha particle activity exceeds five pCi/l the remaining listed radionuclides would be analyzed.							
Turbidity	Units	MCL	MCLG	Highest Level Last 12 Months		Violation (Yes/No)	Source of Substance
Turbidity	NTU	0.3		0.12	0.09	No	Erosion of natural deposits and soil runoff
95% of samples were below the turbidity limits. Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.							
Lead & Copper Monitoring	Units	MCL	MCLG	Distribution System Violations		Violation (Yes/No)	Source of Substance
Lead	ppb	15	0	0		No	Corrosion of household plumbing systems; erosion of natural deposits
Copper	ppb	1300	1300	0		No	Corrosion of household plumbing systems; erosion of natural deposits
Lead and copper are metals found in natural deposits as ores containing other elements. They are sometimes used in household plumbing materials or in water service lines used to bring water from the main to the home. Lead can cause a variety of adverse health effects when people are exposed to it at levels above the action level for relatively short periods of time. These effects may include interference with red blood cell chemistry, delays in normal physical and mental development in babies and young children, slight deficits in the attention span, hearing, and learning abilities of children, and slight increases in the blood pressure of some adults. Lead has the potential to cause the following effects from a lifetime exposure at levels above the action level: stroke and kidney disease; cancer. Copper is an essential nutrient, required by the body in very small amounts. However, EPA has found copper to potentially cause the following health effects when people are exposed to it at levels above the Action Level. Short periods of exposure can cause gastrointestinal disturbance including nausea and vomiting. Use of water that exceeds the Action Level over many years could cause liver or kidney damage. People with Wilson's disease may be more sensitive than others to the effect of copper contamination and should consult their health care provider. State and local government agencies that can be contacted include: Anniston Water Works at 256-241-2000 can provide you with information about your facility's water supply; and the Calhoun County Health Department at 256-237-7523 can provide you with information about the health effects of lead and how you can have your child's blood tested. For more information on reducing lead exposure around your home/building and the health effects of lead, visit EPA's website at http://www.epa.gov/lead or contact your health care provider.							



**DETECTED SUBSTANCES TABLE FOR PERIOD
JANUARY -- DECEMBER 2017 (continued)**

Non-Regulated Contaminants Table	Units	MCL	MCLG	Highest Level Last 12 Months		Violation (Yes/No)	Source of Substance
Methyl tertiary-butyl ether	ppb	Not Regulated		Less than 0.5	Less than 0.5	No	Petroleum products
Total Organic Carbon	ppm	Not Regulated		0.715	2.04	No	Natural sources

Regulated Volatile Chemicals	Units	MCL	MCLG	Highest Level During Last 12 Months		Violation (Yes/No)	Source of Substance
TCE (Trichloroethylene)	ppb	5	0	Less than 0.5	Less than 0.5	No	Discharge from metal degreasing sites and other factories
cis-1,2-Dichloroethylene	ppb	70	70	Less than 0.5	Less than 0.5	No	Discharge from industrial chemical factories
LT2	Units*	MCL	MCLG	Highest Level Last 12 Months		Violation (Yes/No)	Source of Substance
Cryptosporidium, Calc.	organisms/L	TT**	0	0	0	No	Human and animal fecal waste

**Calculated organisms per liter of sample; **Treatment Technique*

MICROBIOLOGICAL SUBSTANCES TABLE FOR PERIOD JANUARY -- DECEMBER 2016

Water Source	Coldwater Spring		Hillabee Reservoir		
Total Coliforms	MCL	MCLG	Highest Level Last 12 Months	Violation (Yes/No)	Source of Substance
Not more than 5% of the 70 monthly bacteriological samples taken can test positive for total coliform. No sample can test positive for fecal coliform or E. Coli.	Less than 5%	0	1.4%	No	Human and animal fecal waste

List of Non-Detect Substances (Anniston Water Works tested for the following substances in 2017 but none were detected.)

Giardia lamblia	Bromochloromethane	Naphthalene	1,1,2-Trichloroethane	Styrene	Mercury	
1,1 - Dichloropropene	Bromoform	N-Propylbenzene	1,1-Dichloroethylene	Tetrachloroethylene	Nickel	
1,1,2,2-Tetrachloroethane	Bromomethane	O-Chlorotoluene	1,2,4-Trichlorobenzene	Toluene	Nitrite	
1,1-Dichloroethane	Chloroethane	P-Chlorotoluene	1,2-Dichloroethane	trans-1,2-Dichloroethylene	Selenium	
1,2,3 - Trichlorobenzene	Chloromethane	P-Isopropyltoluene	1,2-Dichloropropane	Trichloroethylene	Thallium	
1,2,3 - Trichloropropane	Dibromomethane	Sec - Butylbenzene	Benzene	Vinyl Chloride	Color	
1,2,4 - Trimethylbenzene	Dichlorodifluoromethane	Tert - Butylbenzene	Carbon Tetrachloride	Xylenes	Foaming Agents	
1,3 - Dichloropropane	Hexachlorobutadiene	Trichlorofluoromethane	Chlorobenzene	Antimony	Silver	
1,3 - Dichloropropene	Isopropylbenzene	1,1,2-Tetrachloroethane	cis-1,2-Dichloroethylene	Beryllium	Bromoform	
1,3,5 - Trimethylbenzene	M-Dichlorobenzene	Trans 1,3 Dichloropropene	Dichloromethane	Cadmium	Monochloroacetic Acid	
2,2 - Dichloropropane	MTBE	O-Dichlorobenzene	Ethylbenzene	Cyanide	Dibromoacetic Acid	
Bromobenzene	N - Butylbenzene	1,1,1-Trichloroethane	p-Dichlorobenzene			

Important Information to Know about Water

- Substances that may be present in source water include: Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring, or as result from urban run-off, industrial or domestic wastewater discharges, oil or gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water run-off, and residential uses, organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm run-off, and septic tanks.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.
- In order to ensure that tap water is safe, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.
- Some people may be more vulnerable to contaminants in drinking water than the general population. People who are immuno-compromised such as cancer patients undergoing chemotherapy, organ transplant recipients, HIV/AIDS positive or other immune system disorders, some elderly, and infants can be particularly at risk from infections. Those at risk should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791). This information is being provided in addition to other information or notices that may be required by law.

OUR MISSION IS:

- **SERVICE** — by providing high quality drinking water to our customers on demand while maintaining our plants and equipment to facilitate economic growth and development.
- **PROTECTION OF THE ENVIRONMENT AND PUBLIC HEALTH** — through responsible wastewater treatment and source water protection
- **CONTINUOUS IMPROVEMENT** — of our processes and personnel to achieve the highest standards of customer satisfaction and to meet or exceed all water and wastewater quality standards.



Traveling Out of Town?

- * Don't forget to provide us with an updated phone number and email address so we can contact you in an emergency.
- * Don't forget to have someone check your property, inside and out, while you're gone.
- * Don't forget to show your caretaker where your water cut-off valve is.
- * Don't forget to forward your mail and board the pets.



Water and sewer emergencies can happen any time. Make provisions to respond to those events even if you are not around when it happens!

NLC Service Line Warranty Program

The Water Works and Sewer Board of the City of Anniston continues to partner with the National League of Cities (NLC) to provide a Service Line Warranty Program that you can use to protect your water and sewer service lines. The program is administered by Service Line Warranties of America (SLWA) and provides coverage to utility customers for necessary repairs to those lines that the property owner is responsible for.

For more information on this program or to enroll, please visit SLWA's web site at www.SLWofA.com or call 866-722-9006

Water Treatment Process



Drinking water supplied to customers of the Anniston System comes from two sources. Our primary water source is the Coldwater Spring located 7 miles west of Anniston on Tom Burkhart Drive. The Alabama Department of Environmental Management classifies Coldwater Spring as groundwater under the influence of surface water. Water from the spring is treated at the Paul B. Krebs Water Treatment Plant. The statement "under the influence," refers to run off into the uncovered spring pool which is over one acre in size.

Our secondary source of water is the Hillabee Creek Reservoir located 7 miles southeast of Anniston on Jennifer Lane. Hillabee Reservoir is classified as a surface water source. Water from the reservoir is treated at the Earl C. Knowlton Water Treatment Plant located just to the north of the reservoir.

Anniston Water Works has completed a Source Water Assessment for Coldwater Spring and for Hillabee Reservoir. Our assessment has found there is 'Low Susceptibility' to our source waters from elements likely to cause contamination. Our assessment was updated during 2016. Anniston Water Works also owns the Sam H. Hamner Reservoir located 7 miles east of Anniston near the White Plains Community. No water is currently removed from Hamner Reservoir for use in the system.



Anniston Water Works Board of Directors and Management Personnel

Ed Turner, General Manager/CEO	Rodney Owens, Assistant General Manager
Jarrod Simmons, Finance Director	William A. Robison, Chairman
Aaron Acker, Director	Jerome Freeman, Vice Chairman
Betty Merriweather, Director	Ann Welch, Secretary-Treasurer
Brett Rothwell, Director	Melvin Womack, Director

The Board of Directors of the Anniston Water Works consists of four directors appointed by the City of Anniston and three directors appointed by the Calhoun County legislative delegation. The Directors serve for a period of six years with reappointments being made on a staggered basis so all of the members are not replaced during the same year. Board meetings are held on the third Thursday of each month at eleven o'clock in the morning at the Main Office located at 931 Noble Street, Suite 200, Anniston, Alabama. Questions concerning meetings or requests for additional information should be directed to the General Manager and/or Assistant General Manager during normal business hours (Monday-Friday, 7:30 a.m. to 4:30 p.m.) by calling 256-241-2000.

Definitions/Abbreviations Used in this Report

AL	Action Level	The concentration of a contaminant which triggers treatment or other requirements which a water system must follow.
MCL	Maximum Contaminant Level	The highest level of a contaminant that is allowed in drinking water.
MCLG	Maximum Contaminant Level Goal	The level of a contaminant in drinking water below which there is no known or expected health risk.
MRDL	Maximum Residual Disinfectant Level	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG	Maximum Residual Disinfectant Level Goal	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
NS	None Set	No MCL has been set.
NTU	Nephelometric Turbidity Units	A measure of turbidity. Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
pCi/L	Picocuries Per Liter	A measure of radioactivity.
PPM	Parts per Million or milligrams per liter (mg/L)	What is a PPM? Compares to 8 hours and 45 seconds out of a millennium (1000 years).
PPB	Parts per Billion or micrograms per liter (mg/L)	What is a PPB? Compares to 31 seconds out of a millennium (1000 years).
SU	Standard Unit	A measure of pH or acidity.
TT	Treatment Technique	A required process intended to reduce the level of a contaminant in drinking water.

The Alabama Department of Environmental Management (ADEM), with the approval of the United States Environmental Protection Agency (EPA), issued a statewide waiver on monitoring for asbestos and dioxin. Accordingly, Anniston Water Works was not required to monitor for these during the reporting period. Due to the exceptional quality of raw water at Coldwater Spring, the treatment technique at the Paul B. Krebs Water Treatment Plant employs a variance of the filtration rule which was granted by ADEM.

This report is being furnished to you as required by the Safe Drinking Water Act. We are proud to report that your drinking water is safe and meets all requirements of state and federal regulations.

The United States Environmental Protection Agency maintains a Safe Drinking Water Hotline, 800-426-4791, where you can obtain more information about drinking water.

